



CERTIFICAT(E) - BESCHEINIGUNG

This is to certify that

Four Aircoolers 711m²- St.st/Al

has (have) been tested for tightness and strength

Strenght test on tubeside at 35 bar

Leakage test on tubeside at 24 bar

Both tests with air pressure whilst submerged in water.

Leakages and unacceptable distortions were not observed.

Order no. Goedhart : 01-6791-010
Order no. customer : 371535/01080018
Drawing no. : 49697
Type : ADVANTEC 1400-1800 "S"
Capacity : _____ W
Medium : Prop.Glycol
Max. working pressure : 24 bar
Min/Max. working temp. : -55/+55 °C
Tube Volume : 220 dm³
Test date : 10-08-2001

Signed for manufacturer By

Mr. M. Moerland

Goedhart Cooling Equipment B.V.
Nijverheidsweg 6, Sint-Maartensdijk
Postbus 13, 4635 ZG Sint-Maartensdijk
Nederland

Sint-Maartensdijk, 22/08/2001

